SEWAGE GENERATION RATES

Sewage design flows are based on user/occupancy flow generation rates. User/occupancy flow generation rates for the City of Burbank are shown in Table 1. Upon determining the flow generation rates, the City will require a Sewer Capacity Analysis for any proposed flow exceeding 7,500 gallons per day (5.2 gallons per minute), including a peak factor of 2.5 under a future wet scenario, to determine if the existing sewer system has the adequate capacity to convey sewage from the existing properties and the proposed developments. Please refer to the *Design Criteria for Sewer Facilities* (Pending approval) for additional information concerning a Sewer Capacity Analysis.

Table 1 – Sewer Flows

| User/Occupancy Type | Unit of Usage | GPD/Unit |
|---|---------------|----------|
| Group I - Resident | | |
| Multi-Family Apt or Condo | Dwelling Unit | 183.00 |
| Mobile Home Park | Dwelling Unit | 155.28 |
| Single Family Residential | Dwelling Unit | 215.00 |
| Dormitory or Boarding House | Bed | 74.65 |
| Group II - Commercial (Lov | v Strength) | |
| Agricultural/Landscaping Service | 1000 SF | 21.35 |
| Amusement & Recreation Services: Outdoor | Entrant | 8.54 |
| Apparel Product Manufacturing | 1000 SF | 85.39 |
| Apparel and Accessory Store | 1000 SF | 68.31 |
| Auto Parking | 1000 SF | 21.35 |
| Bar or Night Club without Restaurant | 1000 SF | 348.38 |
| Bar or Night Club without Restaurant | Seat | 17.92 |
| Barber Shop | 1000 SF | 85.39 |
| Beauty Shop | 1000 SF | 239.08 |
| Bowling/Skating | 1000 SF | 68.31 |
| Car Wash (Tunnel Area, with Recycling) | 1000 SF | 3236.91 |
| Construction Service (Field Office) | Office | 128.08 |
| Department and Retail Stores (No Restaurants) | 1000 SF | 85.39 |
| Durable Goods - Wholesale Trade | 1000 SF | 68.31 |
| Freight Trucking Services & Warehousing | 1000 SF | 17.08 |
| Furniture and Fixture Manufacturing | 1000 SF | 21.35 |
| Grocery Market w/out Butcher or Baker | 1000 SF | 85.39 |
| Health Services: Hospital | Bed | 170.56 |
| Health Services: Other | 1000 SF | 284.27 |
| Health Services: Psychiatric/Convalescent | Bed | 71.07 |
| Health Services: Surgical | Bed | 426.41 |
| Health Spa | 1000 SF | 234.81 |
| Homeless Shelter | Bed | 71.07 |
| Laundromat, Public | Washer | 287.83 |
| Lumber Yard, Hardware or Gardening Sales | 1000 SF | 85.39 |
| Machine Shop (Excluding Electrical) | 1000 SF | 68.31 |
| Manufacturing, Other | 1000 SF | 68.31 |
| Massage Parlor | 1000 SF | 234.81 |
| Motion Pictures, Indoor Amusement | 1000 SF | 68.31 |
| Motion Pictures/Theater/Auditorium | Seat | 3.42 |
| Museum, Art Gallery | 1000 SF | 17.08 |
| Nursery or Greenhouse | 1000 SF | 21.35 |
| Professional Offices | 1000 SF | 110.12 |
| Railroad Transportation Facility | 1000 SF | 85.39 |

Table 1 – Sewer Flows

| Table 1 – Sewer Flows User/Occupancy Type | Unit of Usage | GPD/Unit |
|--|------------------------|----------|
| Recreational Vehicle Park | Space | 54.75 |
| Restaurant: Preprocessed Food | 1000 SF | 119.44 |
| Shopping Center | 1000 SF | 85.39 |
| Storage, Outdoor | 1000 SF | 21.35 |
| Studios: Production/Recording Sound Stage | 1000 SF | 68.31 |
| Veterinarian | 1000 SF | 239.08 |
| Warehouse Storage, Indoor | 1000 SF | 17.08 |
| Wholesale Trade/Sales | 1000 SF | 85.39 |
| Group II Low Strength Not Listed | 1000 SF | 86.92 |
| Group III - Commercial (Medium Streng | | 00.72 |
| Air Transport Fixed Facility | 1000 SF | 106.50 |
| Bar or Night Club with Restaurant | 1000 SF | 656.27 |
| Beverage Manufacturing | 1000 SF | 948.07 |
| Chemicals & Allied Product Mfg | (a) | 946.07 |
| Hotel, Motel or Lodging (Excluding Dining) | Room | 133.36 |
| Kennel | 1000 SF | 127.84 |
| Laboratory | 1000 SF | 287.88 |
| Laundromat, Commercial | Washer | 143.79 |
| Laundry, Industrial | 1000 SF | 7591.95 |
| Mall (with Food Services) | 1000 SF | 124.91 |
| Medical Lab | 1000 SF | 284.74 |
| Metal Industry | (a) | 204.74 |
| Mortuary | 1000 SF | 154.90 |
| Plastic Product Manufacturing | (a) | 262.32 |
| Printing, Publishing & Allied Industry | 1000 SF | 262.32 |
| Repair Station, Automobile | 1000 SF | 137.38 |
| Service Station, Automobile | Station | 525.59 |
| Textile Manufacturing | (a) | 323.37 |
| Transport Equipment Manufacturing (Including Aircraft) | (a) | 262.32 |
| Water Supply Service | (a) | 262.32 |
| Wood Product Manufacturing | 1000 SF | 41.23 |
| Group III Medium Strength Not Listed | 1000 SF | 102.37 |
| Group IV - Commercial (High Strength | | 102.57 |
| Bakery | 1000 SF | 771.32 |
| Dairy Product Manufacturing | 1000 SF | 1592.39 |
| Food Product Mfg (Industrial) | 1000 SF | 412.94 |
| | to Restaurant and Lodg | l . |
| Paint Manufacturing and Usage | (a) ^b | 1119.00 |
| Restaurant or Deli: Take-out | 1000 SF | 826.42 |
| Restaurant, Cafeteria or Full Service | Seat | 66.11 |
| Restaurant, Fast Food | Seat | 55.09 |
| Restaurant, Other | 1000 SF | 2272.65 |
| Restaurant: Coffee/Donut Shop | 1000 SF | 771.32 |
| Supermarket (Grocery) with Butcher or Baker | 1000 SF | 404.02 |
| Group IV High Strength Not Listed | 1000 SF | 826.42 |
| Cloup 1. Ingh buongai 100 Entre | 1000 51 | 020.12 |

⁽a) Evaluate individual process discharges. Default value is as shown.(b) Evaluate individual process discharges. Default value is as shown.

Sewage Generation Rates Page 3

| Group V – Institutional | | |
|--|----------|--------|
| Church | 1000 SF | 42.69 |
| Church | Seat | 4.27 |
| Community Center (No Kitchen) | Occupant | 3.42 |
| Membership Organizations | 1000 SF | 106.73 |
| Prison with Food Services | Inmate | 186.71 |
| School: Day Care, Elementary & Junior High | Student | 7.59 |
| School: High | Student | 11.39 |
| School: Other | 1000 SF | 151.88 |
| School: Private | 1000 SF | 151.88 |
| School: University or College | Student | 15.19 |
| School: Vocational | Student | 11.39 |
| Social Services | 1000 SF | 124.42 |